Qualitech Testing & Consultancy Limited
匯駿檢測及顧問有限公司
Flat E & F, 9/F, Block B, Universal Industrial Centre,19-25 Shan Mei Street, Sha Tin, Hong Kong.
新界火炭山尾街19-25號宇宙工業中心B座9樓E&F室
Tel : (852) 2185-0900 Fax : (852) 2687-6752 Website : www.qtc-hk.com E-mail : qtc@qtc-hk.com

Test Report

Customer's Name: Global Oxygen Health

Customer's E-mail:

Test Period: 9 to 11 September, 2025

Sample ID 樣本編號	Test Items 檢測項目	*Reference Standard 參考標準	Result 結果	Unit 單位	Normal	High Risk
安裝水機前	HPC 總菌數	≤ 20	**>5 700**	cfu/mL	*Normal*	*High Risk*
	E.coli 大腸桿菌	< 1	**0**	cfu/100mL	*Normal*	*High Risk*
	Antimony 銻	≤ 20	**0.5**	µg/L	*Normal*	*High Risk*
	Arsenic 砷	≤ 10	**<1**	µg/L	*Normal*	*High Risk*
	Barium 鋇	≤ 1300	**20**	µg/L	*Normal*	*High Risk*
	Boron 硼	≤ 2400	**32**	µg/L	*Normal*	*High Risk*
	Cadmium 鎘	≤ 3	**<0.5**	µg/L	*Normal*	*High Risk*
	Chromium 鉻	≤ 50	**<1**	µg/L	*Normal*	*High Risk*
	Copper 銅	≤ 2000	**230**	µg/L	*Normal*	*High Risk*
	Lead 鉛	≤ 10	**<1**	µg/L	*Normal*	*High Risk*
	Manganese 錳	≤ 80	**5.6**	µg/L	*Normal*	*High Risk*
	Mercury 汞	≤ 6	**<0.1**	µg/L	*Normal*	*High Risk*
	Nickel 鎳	≤ 70	**40**	µg/L	*Normal*	*High Risk*
	Selenium 硒	≤ 40	**<10**	µg/L	*Normal*	*High Risk*
	Iron 鐵	≤ 300	**<10**	µg/L	*Normal*	*High Risk*

***Remark :** Reference standard is from Water Supplies Department. 參考標準來自水務署。

Disclaimer : Any information listed and figures calculated on this report are for reference only. They are not intended as a substitute for accreditated test report.
數據只供參考用途；並不可視為取代專業認可測試報告。

Qualitech Testing & Consultancy Limited
匯駿檢測及顧問有限公司
Flat E & F, 9/F, Block B, Universal Industrial Centre,19-25 Shan Mei Street, Sha Tin, Hong Kong.
新界火炭山尾街19-25號宇宙工業中心B座9樓E&F室
Tel : (852) 2185-0900 Fax : (852) 2687-6752 Website : www.qtc-hk.com E-mail : qtc@qtc-hk.com

Test Report

Customer's Name: Global Oxygen Health

Customer's E-mail:

Test Period: 9 to 11 September, 2025

Sample ID 樣本編號	Test Items 檢測項目	*Reference Standard 參考標準	Result 結果	Unit 單位		
安裝水機後	HPC 總菌數	≤ 20	**0**	cfu/mL	*Normal*	*High Risk*
	E.coli 大腸桿菌	< 1	**0**	cfu/100mL	*Normal*	*High Risk*
	Antimony 銻	≤ 20	**<0.5**	µg/L	*Normal*	*High Risk*
	Arsenic 砷	≤ 10	**<1**	µg/L	*Normal*	*High Risk*
	Barium 鋇	≤ 1300	**15**	µg/L	*Normal*	*High Risk*
	Boron 硼	≤ 2400	**29**	µg/L	*Normal*	*High Risk*
	Cadmium 鎘	≤ 3	**<0.5**	µg/L	*Normal*	*High Risk*
	Chromium 鉻	≤ 50	**<1**	µg/L	*Normal*	*High Risk*
	Copper 銅	≤ 2000	**61**	µg/L	*Normal*	*High Risk*
	Lead 鉛	≤ 10	**<1**	µg/L	*Normal*	*High Risk*
	Manganese 錳	≤ 80	**<5**	µg/L	*Normal*	*High Risk*
	Mercury 汞	≤ 6	**<0.1**	µg/L	*Normal*	*High Risk*
	Nickel 鎳	≤ 70	**2.3**	µg/L	*Normal*	*High Risk*
	Selenium 硒	≤ 40	**<10**	µg/L	*Normal*	*High Risk*
	Iron 鐵	≤ 300	**<10**	µg/L	*Normal*	*High Risk*

***Remark :** Reference standard is from Water Supplies Department. 參考標準來自水務署。

Disclaimer : Any information listed and figures calculated on this report are for reference only. They are not intended as a substitute for accreditated test report.
數據只供參考用途；並不可視為取代專業認可測試報告。